

Return address: P.O. box 337, 7500 AH Enschede, The Netherlands

Superior Manufacturing Group – Europe B.V.
Att. Mrs. G. Dirckx
Achterzeedijk 57
2992 SB
Barendrecht
The Netherlands

TÜV Rheinland Nederland B.V.
The Netherlands

Postal address:
P.O. Box 337
7500 AH Enschede

Parking and delivery:
Josink Esweg 10
7545 PN Enschede

www.tuv.com/nl

T +31 88 888 7888
F +31 88 888 7859

lse.pierik@nl.tuv.com

REPORT

Project number: 89203899
Report number: 89203899.02en

Date
August 26, 2013

Received:
A PVC mat, a floor covering, marked as: "539 Gripwalker";
TÜV-reference MT13-37805.02.

Project number
89203899

Report number
89203899.02en

Dimensions : Mat, square of 910 x910 mm
Total thickness : 11 mm*
Weight : 8.5 kg/m²
Material : PVC *

Phone number client
+31 18 064 3115

* Applicant's declaration from product specification sheet, august 2013.

Fax number client
+31 18 061 1551

Sampling procedure:
The samples are selected by the applicant.
The test house has had no influence on the sampling

Article
PVC mat: Gripwalker

Order:
To determine the slip resistance according to DIN 51130, ramp test.
The space of displacement is not determined.

Appendix
-none-

Results:
See page two.

Appendix:
None

TRN applies General Terms &
Conditions which are filed at the office of
the Clerk for civil affairs at the Court in
Zulphen (the Netherlands) under number
35/2010, dated November 17th 2010.

RESULTS

Slip resistance

Method DIN 51130:2010-10

Testing location: TÜV Rheinland – Nürnberg.

Date of testing: August 13, 2013.

Date
August 26, 2013

Project number
89203899

Report number
892023899.02en

Article
PVC mat: Gripwalker

Page
2/2

Walking angle, α_{ges} : 12.1°
Slip resistance classification : R10*

* R9 requirement = $10^\circ \leq \alpha_{ges} \leq 19^\circ$

Author:
Mrs. I. Pierik



26-8-2013

Visa:
Mr. J. Brinks



All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V.

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.

© 2010 TÜV Rheinland Nederland B.V.