

Return address P.O. box 337, 7500 AH Enschede, The Netherlands

Superior Manufacturing Group – Europe B.V.
Att. Mrs. G. Dirckx
Achterzeedijk 57
2992 SB
Barendrecht
The Netherlands

TÜV Rheinland Nederland B.V.
The Netherlands

Postal address:
P.O. Box 337
7500 AH Enschede

Parking and delivery:
Josink Esweg 10
7545 PN Enschede

www.tuv.com/nl

T +31 88 888 7888
F +31 88 888 7859

Jaring.de.Wolff@nl.tuv.com

REPORT

Project number : 89206867
Report number : 89206867.01en

Date
November 10, 2014

Received:

An floor covering product, anti-slip gritted mat, marked as: **“681 Grit Trax”**;
TÜV-reference MT14-49890.01.

Project number
89206867

Report number
89206867.01en

Product specifications received from the applicant

Total thickness (mm) : 2.1
Weight (kg/m²) : 2.3
Material : Disilicon trioxide

Phone number client
+31 180 643 115

Fax number client
+31 180 611 551

The samples have been received on 7th of October 2014. The samples are selected by the applicant. The test house has had no influence on the sampling procedure.

Order:

To determine the slip resistance according to DIN 51130, ramp test.
The space of displacement is not determined.

Article
681 Grit trax

Appendix
-none-

Results:

See page two.

Appendix:

None

TRN applies General Terms & Conditions which are filed at the office of the Clerk for civil affairs at the Court in Zutphen (the Netherlands) under number 35/2010, dated November 17th 2010.

RESULTS

Slip resistance

Method DIN 51130:2013-5

Testing location : Subcontracted to an accredited laboratory.
Date of testing : 29-10-2014

Mean angle of acceptance, α_{ges} : 38.8°

Slip resistance classification : R13*

* R13 requirement = $\alpha_{ges} > 35^\circ$

Date
November 10, 2014


Project number
89206867

Report number
89206867.01en

Article
681 Grit trax

Page
2/2

Author:
Mr. J. de Wolff



Visa:
Mrs. I. Pierik



All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V. The results are based upon the samples received and have not to be representative for the total production. Besides TÜV Rheinland Nederland B.V. had no influence on the sampling

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.