TÜV Rheinland Nederland B.V.



Return address: P.O. box 337, 7500 AH Enschede, The Netherlands

Superior Manufacturing Group – Europe B.V. Att. Mrs. G. Dirckx Achterzeedijk 57 2992 SB Barendrecht The Netherlands

REPORT

Project number: 89203899 Report number: 89203899.01en

Received:

A PVC mat, a floor covering, marked as: "537 FLEXDEK"; TÜV-reference MT13-37805.01.

Dimensions

: Mat, square of 910 x910 mm

Total thickness

: 12 mm* : 7.5 kg/m²

Weight Material

: PVC *

Sampling procedure:

The samples are selected by the applicant.

The test house has had no influence on the sampling

Order:

To determine the slip resistance according to DIN 51130, ramp test. The space of displacement is not determined.

Results:

See page two.

Appendix:

None

TÜV Rheinland Nederland B.V. The Netherlands

Postal address: P.O. Box 337 7500 AH Enschede

Parking and delivery: Josink Esweg 10 7545 PN Enschede

www.tuv.com/nl

T +31 88 888 7888 F +31 88 888 7859

Ilse.pierik@nl.tuv.com

Date

August 26, 2013

Project number 89203899

Report number 89203899.01en

Phone number client

+31 18 064 3115

Fax number client +31 18 061 1551

Article

PVC mat: Flexdek

Appendix

-none-

TRN applies General Terms &
Conditions which are filed at the office of
the Clerk for civil affairs at the Court in
Zutphen (the Netherlands) under number
35/2010, dated November 17th 2010.

st Applicant's declaration from product specification sheet, august 2013.



Date

Article

Page

2/2

August 26, 2013

Project number 89203899

Report number 892023899.01en

PVC mat: Flexdek

RESULTS

Slip resistance Method DIN 51130:2010-10

Testing location: TÜV Rheinland – Nürnberg. Date of testing: August 13, 2013.

Walking angle, α_{ges}

: 16.5°

Slip resistance classification : R10*

* R9 requirement = $10^{\circ} \le \alpha_{ges} \le 19^{\circ}$

Author: Mrs. I. Pierik

All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V.

Visa:

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.

© 2010 TÜV Rheinland Nederland B.V.