

Trade name continue

<u>Model:</u>	<u>Dimension grating</u>	<u>RSK-number:</u>
Purus Sigyn 75 R	Ø150 mm	711 80 85
Purus Sigyn 75 R NOOD	Ø150 mm	715 24 80

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this type approval, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Waste water installations*	6:641, 1 st and last sentence in 2 nd paragraph
Design	6:644, 1 st sentence and 2 nd paragraph

*Wastewater installations must be designed so that they can continuously divert at least 150% of the standard flows of the served tapping points.

Associated documents

Installation instruction Purus floor gullies 227 33 dated 2022-10-18.
Maintenance of gullies and stainless steel channels- general, version 2023.

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control plan: Appendix A dated 2020-07-03 to control agreement 351. Inspection body: DTI

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing place

Production control includes the following place:
Purus AB, Södra Dragongatan 15, SE-271 39 Ystad, Sweden

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Packing is marked:

Holder	Purus
Product type designation	<i>according to trade name</i>
Consecutive manufacture number	<i>number</i>
Type approval number	5314/91
Boverket's registered trade mark	†
RISE Accreditation number	1002
Certification body	RISE
Inspection body	351, DTI

Product is marked:

Holder	Purus
Consecutive production month/year	<i>mm/yy</i>

Type Approval 5314/91 | 2024-11-14

RISE Research Institutes of Sweden AB | Certification

Basis for approval

Report VTT-S-00918-17 from VTT.
Reports 869826-1 rev1 och 177233 from DTI.

Comments

Purus Balder and Purus Sigyn are approved according to standard SS-EN 1253-1.
The removable water trap needs to be cleaned regularly.

Associated documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2023-09-29.

Validity

Valid through 2028-09-28.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

A handwritten signature in blue ink, appearing to read 'Stefan Coric'.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.