

Associated documents

Installation instruction Purus MiniMax Two Part, dated 2019:1.

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Appendix A to control agreement 351. Inspection body: DTI

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing place

Production control includes the following place:

BLS Industries AB, Södra Dragongatan 15, 271 39 Ystad, Sweden.

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Packing is marked with:

Holder	Purus
Product type designation	MiniMax Two Part
Type approval number	SC1586-12
Boverket's registered trade mark	✚
RISE Accreditation number	1002
Inspection body	DTI

Product is marked with:

Holder	Purus
Consecutive production month/year	month/year

Basis for approval

Reports PX21874-A and PX21874-1 from SP.

Reports 120713-1 and 251425 from RISE.

Comments

Floor gullies are judged to fulfil the requirements of EN 1253-1 except minimum flow rate (0.8 l/s). However, requirement for installations with one shower head (0.4 l/s) is fulfilled. Depth of water trap is less than 50 mm but the partially mechanical water trap is judged to correspond to a water trap depth of 50 mm. The water trap should be cleaned regularly.

Associated documents shall accompany the product or by other means be available to users of the product.

Validity

Valid through 2029-10-16.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

A handwritten signature in blue ink, appearing to read 'Stefan Coric'.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.