

















2.4 & 1.0 TERMINAL & WIRE APPLICATION REQUIREMENTS



DELPHI MES 2.4 TERMINAL - 13783284 OR EQUIVALENT WITH GOLD PLATED INTERFACE FOR POWER CIRCUITS.
DELPHI MES 1.0 TERMINAL - 13717949 OR EQUIVALENT WITH GOLD PLATED INTERFACE FOR SIGNAL CIRCUITS.

1. 325A CONTINUOUS CURRENT APPLICATIONS REQUIRE 5.0 - 6.0 mm² COPPER CONDUCTORS ON THE 2.4 TERMINALS.
2. GOLD PLATED TERMINAL INTERFACES ARE REQUIRED TO MEET USCAR-2 CONNECTOR ELECTRICAL CRITERIA.
3. TERMINAL TEMPERATURES NEED TO BE MEASURED IN THE APPLICATION TO ENSURE THE FOLLOWING:
   - TERMINAL TEMPERATURE RISE OVER AMBIENT IS ≤30°C AT MAXIMUM CONTINUOUS CURRENT.
   - TERMINAL TEMPERATURE (AMBIENT + RISE) IS ≤125°C AT MAXIMUM CONTINUOUS CURRENT AND MAXIMUM AMBIENT.
4. ELECTRIC VEHICLE CHARGING APPLICATIONS REQUIRE WIRE TO TERMINAL INTERFACE RESISTANCE ≤0.2 mOhms.
   - SOLDERED CRIMPS ARE RECOMMENDED.

SYMBOL DEFINITION		MISSING SYMBOLS
A DIMENSION WITHOUT AN INSPECTION REPORT SYMBOL — DOES NOT REQUIRE INSPECTION. IT MAY BE CONTROLLED ON THE INDIVIDUAL COMPONENT DRAWINGS.	TOTAL NO OF INSPECTIONS REQUIRED: 27	NO MISSING SYMBOL NUMBER
	LAST NO. USED: 29	

ENG LEVEL DATE	LTR	SECT/ZONE	ITEM	ECN#	REVISION HISTORY	MFR	MFR PART #
08MAY13	B	B1			ASS RELEASED AND RELEASED	414055	13783284
26JUL13	P	B2	-	-	ALL PARTS: ADDED EIN AN NO MFR ONLY TERMINAL	414934	13783284
31JAN12	P	B3	-	-	ALL PARTS: ADDED APPLICATION INFO, SEE NOTES #3, 4, 5, & 7	414981	13783284
16MAY13	P	B4	-	-	ALL PARTS: ADDED "TERMINAL & WIRE" VIEW AND UPDATED "REFERENCE MATING" NOTE	422351	13885884
13NOV13	P	B5	-	-	CORRECTED ISOMETRIC VIEW	422511	14553144
28FEB14	P	B6	-	-	1134.1 - INCLUSIVE DRAWING ALL PARTS - UPDATED "TERMINAL & WIRE" VIEW	423694	13885884
01JUL14	P	B7	-	-	1134.1 - UPDATED PART AVAILABILITY	423334	13885884
16MAR15	P	B8	-	-	REVISED TERMINAL & WIRE APPLICATION REQUIREMENTS NOTE	424547	13783284
04AUG14	P	B9	-	-	ALL PARTS - ADDED ORDERING INFORMATION NOTE	427118	13885884
18FEB16	P	B10	-	-	1132.1 - 77 & 78 - RELEASED	428838	13885884
30AUG16	P	B11	-	-	1132.1 - 79 - UPDATED PART AVAILABILITY	432351	13885884
25AUG16	P	B12	-	-	1132.1 - 80 & 1134.1 - OBSOLETE AND ADDED "REPLACED BY" INFO	434886	13885884
27SEP16	P	B13	-	-	1132.1 - 81 - RELEASED AND REMOVED "REPLACED BY" INFORMATION	435825	13885884
10DEC16	P	B14	-	-	1132.1 - OBSOLETE AND ADDED "REPLACED BY" INFORMATION	437286	13885884

PART NO	REV	N/P	TYPE	HEADER CONNECTOR	PLR	BUSHING	SEAL	REPLACED BY
13885884	01	A1	101	13829692	13812743	13811751	13829713	-
13885884	01	A2	101	13829692	13812743	13811751	13829713	-
13885884	01	A3	101	13829692	13812743	13811751	13829713	-
13885884	01	A4	101	13829692	13812743	13829694	13829713	-
13885884	01	A5	101	13829692	13812743	13829694	13829713	13829378
13885884	01	A6	102	13829692	13812743	13829694	13829713	13829377
13885884	01	A7	101	13829692	13812743	13829694	13829713	13829376

NOTES

1. UNLESS OTHERWISE SPECIFIED AND/OR INDICATED:
   DIMENSIONS ARE TO FACE OF VIEW SHOWN AND AUTOMATICALLY PROBED BY COMPUTER FOR INSPECTION (SEE MATH MODEL FOR PRECISE DIMENSIONS) - FOR ALL OTHER DIMENSIONS NOT SHOWN BUT REQUIRED FOR TOOL BUILD, SEE MATH MODEL FOR PRECISE TOOL PATH DATA.
2. THIS PRODUCT IS NOT CATEGORIZED AS AN APPEARANCE ITEM. MINOR APPEARANCE DEFECTS (SCRATCHES, DENTS, ETC.) ARE ACCEPTABLE AS LONG AS FUNCTION, FIT, FORM, OR FUNCTION OF THE PART ARE NOT AFFECTED. SEE GMW 14078 FOR ADDITIONAL INFORMATION.
3. CONNECTOR ASSEMBLIES ARE VALIDATED TO SAE/USCAR-37 REV.(C) - AUG.'08 TEMPERATURE CLASS TI, SEALING CLASS S4, VIBRATION CLASS V1, AND MATING CYCLES M1.
4. SEAL MAY BECOME DISLODGED DURING SHIPPING AND HANDLING. BEFORE ATTACHING TO THE MATING DEVICE OR COVER, THE OPERATOR MUST ENSURE THE SEAL IS INTACT AND PROPERLY ADHERE TO AN SURFACE.
5. RECOMMENDED FASTENER TIGHTENING TORQUE IS 3.5 +/- 0.5 NEWTON-METERS.
6. HARNESS MANUFACTURER IS RESPONSIBLE FOR VALIDATING THE CONNECTION AS APPLIED OR CABLE TO THE REQUIREMENTS OF SPECIFIC APPLICATIONS.
7. REFERENCE MATING COMPONENTS OR EQUIVALENT:
   MODULE CASE DETAIL - 13943505
8. FOR APPLICATION DATA SEE THE INDIVIDUAL APPLICATION DRAWINGS.
9. CONNECTOR DESIGNS PROVIDE THE FOLLOWING MINIMUM CREEPAGE DISTANCES BETWEEN TERMINALS, AS DETERMINED PER ISO60664 WITH POLLUTION DEGREE 2 OR 3:
   - CAVITIES 1 TO 4 OR 2 TO 6 = 10.36
   - CAVITIES 1 TO 3 OR 4 TO 6 = 16.84
   - CAVITIES 1 TO 6 OR 4 TO 3 = 19.09

DELPHI

DELPHI PACKARD ELECTRICAL/ELECTRONIC ARCHITECTURE

DRAWING TYPE	PART DRAWING
SIZE	A3
UNLESS OTHERWISE SPECIFIED	
DIMENSIONS ARE IN MILLIMETERS	
ANGLES ± 0.5°	
XX ± 0.25	
XXX ± 0.127	
XXXX ± 0.0127	
SURFACE FINISH 1.6	
DRAWING IS A PROPRIETARY DOCUMENT OF DELPHI PACKARD ELECTRICAL/ELECTRONIC ARCHITECTURE SA. THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF DELPHI PACKARD ELECTRICAL/ELECTRONIC ARCHITECTURE SA. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF DELPHI PACKARD ELECTRICAL/ELECTRONIC ARCHITECTURE SA IS PROHIBITED.	

MATERIAL	SEE SHEET
FINISH	SEE SHEET
GENERIC NAME	1X41 ASM STRIP 0 W MES 1.0 2.4 SLD MODULAR
DRAWING NUMBER	13885884
SHEET	A1/2 | 01 | 01 OF 2 | REV 14

13885884