

Delta 12 AHU Technical Information

Specialist Design, Support and H & V solutions for all wet leisure projects



Solutions for:

- Humidity control
- Pool water heating
- Ventilation
- Air cooling
- Recovering energy
- Air heating



Specification - Model Delta 12 - General

Supply one specifically designed swimming pool heat recovery and dehumidification unit as follows: -

Unit comprising: -

- Galvanised and plastisol coated insulated steel cabinet, panels with quick release fasteners, mounted on a hot dip galvanized chassis.
- Variable speed, EC main recirculation fan.
- Variable speed, EC exhaust air fan.
- · Filters for recirculation and fresh air inlets.
- Fresh air louvre dampers driven by a controlled positioning motor, for automatically regulated introduction of fresh air, set to provide pool hall negative pressure.
- Heat pump dehumidifier for the recirculation and exhaust airflows incorporating heat recovery to pool water and pool hall air.
- Fully controlled LPHW air heater battery.
- Fully controlled LPHW pool water calorifier.
- Integral control panel complete with sensors and controllers for:
 - Humidity
 - Air temperature
 - Pool water temperature
 - Comprehensive running and fault indicators
 - Network connection via RJ45 interface
- Optional features

Specification - Model Delta 12 - Detail

Chassis and Cabinet

The chassis shall be fabricated from cold rolled mild steel section hot dip galvanized. The cabinet shall be formed from galvanised and plastisol coated steel sheet and insulated internally with expanded P.V.C. foam sheet, type 3509, having density of 260 kg/m³ and thermal conductivity K = 0.043 W/mK.

The unit shall be totally insulated and panels shall be removable for service and for access to fresh air and recirculation filters. Panels shall be manufactured from galvanised steel sheet with outer sides having plastisol coating, Leathergrain. The inside shall be insulated as previously described. Service panels shall have quick release fasteners.

The whole construction of the unit shall be designed to withstand the corrosive atmosphere normally experienced in a swimming pool building. A compact solution, the unit shall come as one piece, overall size 1840mm long x 854mm wide x 1960mm high

Main Recirculation Fan

The main recirculation fan shall be capable of circulating 7,000 m³/h (1.94 m³/s) pool hall air against an external total pressure of 50mm wg. It shall be driven by an electronically commutated motor. The motor shall be protected by a 3 phase motor start circuit breaker. The main fan shall run continuously.

Exhaust Air Fan

The exhaust air fan shall be capable of exhausting up to 3,500 m³/h (0.97m³/s) used air against an external total pressure of 50mm wg. It shall be driven by an eletrically commutated motor. The motor shall be protected by a 3 phase motor start circuit breaker. The exhaust fan shall run continuously.

Air Filters

The unit shall be complete with recirculation and fresh air filters which shall be easily changed. The filters shall be 50mm deep disposable panel filters, bonded glass fibre type with an EN 779 classification of G2.

Exhaust/Fresh Air Dampers

Exhaust air delivered by the exhaust fan to atmosphere shall be quantitatively varied by the exhaust fan. Fresh air shall be varied by an inlet damper, both driven by a dedicated multi-position control motor. The dampers shall be galvanised geared units of high quality construction and shall be set such that the inlet damper opens slightly less than the exhaust to ensure a pool hall negative pressure. Signal for the control motor shall be provided from the integral control panel. The exhaust air volume shall be automatically modulated by the control system from a minimum flow of 350m³/h up to a maximum of 3,500m³/h, which shall be influenced by the following parameters:-

- The pool hall humidity
- The pool hall temperature
- The external ambient temperature
- The air quality sensor (if fitted) detecting deterioration of the pool hall air condition

Heat Recovery Heat Pump Dehumidifier

The heat pump shall be capable of acting as a heat recovery dehumidifier from the recirculating and exhaust air when required, and as a refrigerated air conditioning unit when the pool air conditions rise above the pool hall temperature set point. It shall be automatically controlled from the integral control panel.

It shall have a net heat recovery capacity of 17.6kW at pool conditions of 28°C and 60%RH. During heat recovery the energy shall be capable of being fed into the pool water and/or air. During air conditioning, the recovery energy shall be automatically directed to the pool water and/or rejected at the exhaust air condenser whichever is appropriate.

Evaporators and air condensers shall be of copper tube with aluminium fins protected by high integrity polyester coating. Pool water condenser shall be a seamless tube-in-tube coaxial unit manufactured from extended surface 90/10 cupro-nickel where in contact with the pool water.

Auxiliary air heating

An LPHW air heater battery with fully controlled valve shall be provided, rated at 42kW, to provide heat to the air stream, with 34.7kW available for building fabric losses with fresh air at -5°C. The heat output shall be rated with LPHW supplied from an external source at a flow temperature of 80°C. The heater battery shall be of copper tube with aluminium fins protected by high integrity polyester coating.

Auxiliary pool water heating

An LPHW pool water calorifier with fully controlled valve shall be provided, rated at 40kW, to provide top up heat to the pool water to make up unrecoverable losses. The heat output shall be rated with LPHW supplied from an external source at a flow temperature of 80°C. The heat exchanger shall be manufactured from 316 stainless steel.

Specification - Model Delta 12 - Controls

The control panel shall be integral with the unit and all necessary sensors, controllers, motor starters, overloads and circuit breakers shall be integrated within the cabinet. The unit shall control the following parameters:-

- Humidity 2 stages
- Air temperature 3 stages (including unoccupied set-back)
- Pool water temperature 2 stages

Control of humidity, air temperature and water temperature shall be by PLC digital controllers which shall provide displays of actual and set point readings. An integral time clock shall be provided to work in conjunction with the third air temperature stage to cater for unoccupied air temperature set back for energy economy, if a pool cover is used.

A 2-position ON-OFF function shall be provided on the control panel.

A 2-position WATER-AIR function shall be provided on the control panel to override heat recovery priority.

A 2-position ENABLE-DISABLE function shall be provided on the control panel to allow manual override of air conditioning operation.

A 3-position MAX-AUTO-MIN function shall be provided on the control panel to allow manual override of fresh air operation.

Warning indicator lights shall be provided on the control panel to indicate the following conditions:-

•	Mains	ON
---	-------	----

- Compressor Fault
- Compressor Defrost
- Fresh air operation Auto

Indicator lights shall be provided on the control panel to indicate when the machine is providing:-

- Dehumidification by heat pump
- Air heating via LPHW
- Air cooling by heat pump
- Water heating via LPHW

The following remote contacts shall be available at the main terminal block to provide the following control interfaces: -

- Indication of auxiliary water heater or air heater in operation, requiring LPHW to be supplied (volt-free contacts) - can control a dedicated boiler to switch ON or OFF as determined by machine or to control a 3 port bypass valve if required.
- Indication that pool pump is required to run (12V supplied from machine) can control a dedicated pool
 water pump to come on only when required for heat recovery to pool water or auxiliary water heating.

• Remote override of occupied/unoccupied mode (12V supplied from machine) - can override the integral time

clock to put the control system into occupied mode when pool is uncovered.

The following volt-free pairs shall be available to provide remote indication of:-

- Machine on
- Main fan running
- Exhaust fan running
- Compressor running
- Compressor fault

An ambient air temperature control shall be provided in the fresh air inlet to control reduction of fresh air quantity in cold weather at an adjustable threshold.

An air ttemperature control shall be provided to control the unoccupied air temperature.

A pool water pressure switch shall be provided to detect loss of pool water flow.


A flow meter shall be provided to indicate the pool water flow through the heat recovery condenser.

A phase rotation protection relay shall be provided on three phase machines to prevent operation in the event of incorrect phase rotation.

Optional features


The following optional features shall be available on request: -

- The main and/or exhaust fan speeds can be varied to provide increased external static pressure.
- Air differential pressure switches can be fitted across main and/or exhaust fans to detect fan pressure and provide a fan failure signal.
- Air differential pressure switches can be fitted across recirculation filters to detect the filter pressure drop and provide a filter dirty signal.
- An air quality monitor can be provided to detect deterioration in pool hall air condition and force the maximum quantity of fresh air to be introduced.
- The LPHW air heater battery can be upgraded to compensate for lower LPHW flow temperatures.
- The LPHW air heater battery can be provided with frost protection to force the minimum quantity
 of fresh air to be introduced.
- The digital controllers can be provided with an optional RS485 interface using a MODBUS protocol, thus allowing interface with a BMS to monitor and alter set point values remotely.
- The air temperature and humidity sensors can be fitted in a remote sensor enclosure to provide remote measuring of pool hall relative humidity and air temperature.
- · The compressor can be fitted with a soft-start.




DELTA MODEL 10 & 12

(OPPOSITE HAND)



BOTTOM VIEW (BASE)



Data Sheet - Delta 12

Dehumidification Duty			Electrical		
Via Heat Pump (28ºC / 60%rh) (Dampers Min)	l/hr	14	Total Power Consumed (Nominal)	kW	7.4
Total @ 18ºC Dewpoint (Summer) (Damper Max)	l/hr	21	Min Supply Capacity (Max FLA) 3ph N	amps	23
Total @ 7°C Dewpoint (Winter) (Damper Mid)	l/hr	28.2	Max Supply Fuse 3ph N	amps	32
VDI 2089	l/hr	22.2			
Total DH + VDI 2089 @ 12.5ºC					
Dewpoint (Summer)	l/hr	29.2	Main Fan		
			Air Flow	m³/hr	7000
Heat To Air			Max Internal Static Pressure	mmWg	50
Via Heat Pump (Mode A)	kW	2.5	FLA 3ph N - Single Speed	amps	4.6
Via Heat Pump (Mode B)	kW	12.1			
Via LPHW @ 80 ⁰ C	kW	42			
Total	KW	44.5/54.1	Exhaust Fan		
			— Air Flow (Summer)	m³/hr	3500
Building Heat Loss			Air Flow (Winter)	m³/hr	1750
Heat Required For Fresh Air @ -5ºC	kW	19.4	Air Flow (Unoccupied)	m³/hr	350
Available For Fabric Losses @ -5ºC	kW	34.7	Max External Static Pressure FLA	mmWg	50
			— 3ph N - Single Speed	amps	4
Heat To Pool Water					
Via Heat Pump (Mode A)	kW	15			
Via Heat Pump (Mode B)	kW	5.5	Compressor		
Via LPHW @ 80ºC	kW	40	Nominal Power Consumed	kW	4.2
Total	kW	55/45.5	LRA 3pH N	amps	101
Flow Rate Pool Water ± 10%	l/min	54	RLA 3ph N	amps	8.9
Pressure Drop @ Rated Flow m/hd 3.5		Soft Start Amps 3ph N	amps	34	
Max Working Pressure	bar	3.5			
Internal Condenser Taco Pool Water Setting	l/min	29	General Data - Hermetic System		
			Gas Charge (R407c)	kg	8
Cooling Duty	mode	A/B	Weight Approximately	kg	460
Cooling Duty (Sensitive)	kW	- 7.1			
Cooling Duty (Total)	kW	- 10.1			
Recommended Boiler Capacity	kW	82	7		
Flowrate	l/min	53			
Pressure Drop @ Rated Flow	m/hd	2.8			
Max Delta System Working Pressure	bar	6			

For accurate application sizing please consult Calorex Heat Pumps Ltd

Mode A = recovered heat biased to pool water (Pool water temp not satisfied) Mode B = recovered heat biased to pool hall air (pool water temp satisfied) R407c Global Warming Potential (GWP) 1700 1mm WG = 9.8 Pa 1m hd = 1.4 psi 11/min = 0.22 gal/min

Warranty Conditions

The following exclusion apply to the Warranty given by Calorex Heat Pumps Ltd No claims will be accepted if:

- 1. The Heat Pump is incorrectly sized for the application
- 2. The Heat Pump is installed in any way that is not in accordance with the current procedures as defined by Calorex Heat Pumps Ltd
- 3. The Heat Pump has been worked upon or is adjusted by anyone other than a person authorised to do so by Calorex Heat Pumps Ltd
- 4. The air flow to and from the machine is outside the specified limits
- 5. The water flow through the machine is outside the specified limits
- 6. The water pH level and / or chemical balance is outside the following limits Acidity 7.2-7.8 pН Total Alkalinity as CaCO₃ ppm 80-120 Total Hardness as CaCO₃ 150-250 ppm **Total Dissolved Solids** 1000 ppm Maximum Salt Content ppm 8000 **Free Chlorine Range** 1-2 Domestic ppm **Free Chlorine Range** ppm 3-6 Commercial Superchlorination 30ppm for 24 hours max **Bromine** 2-5 ppm Baquacil 25-50 ppm Ozone 0.9 Max ppm **Max Copper Content** 1 ppm Aquamatic Ionic Purifier 2 Max ppm
- 7. The Heat Pump has suffered frost damage
- 8. The electrical supply is insufficient or in any way incorrect
- 9. The fan amps and duct pressure are outside the specified limits

10. The Heat Pump must be maintained in accordance with service requirements in section 2.6. For details of the extended warranty and maintenance packages please call H & V Divison.



Office Use Only:	
Order No:	
Part No:	
Price	
Carriage	

Order Confirmation Form For A Delta

Many thanks for your valued order for a Delta Swimming Pool Control Unit Please specify configuration required below then confirm it is correct by signing and returning to us on

Fax number 01993 778869

To:	From:
Company:	Date:
Fax:	Ref:

Delta Model (* available in 3ph only)	Standard - Available in all models	Mirrored - Available in models 4-16			
1	Top Outlet Fresh Air Option For Supply Fresh Air	Fresh Air Top Quilet			
2	Odoton For Supply Fresh Air Supply Air Exhaust	Fresh Air Supply Option For Exhaust Supply Air			
4	Digitizy Panel Buctrical Access Panel • •	P P Districut Panal Districut Panal			
6	End Outlet Option For Supply Air				
8 *	Ciril Ouler Option For Contract Contrac	Return Air From Pool Hall Barrise Panel Ba			
10 *					
12 *		Bottom Outlet Option For Supply Air			
14 *	Bottom Outlet Option For Supply Air				
16 *					
Single Phase Y / N	Three Phase Y / N Air Off:	Top End Bottom			

If the above does not correspond to your requirements please contact Certikin H & V Department to discuss options, alternatively, please liaise with your local distributor.

I confirm the above Delta configuration and sepcifications meet my requirements and that the unit is non-refundable for reasons of incorrect configuration / specification.

Please Note: If the unit is in stock for more than 14 days after the above date, an invoice for 50% of the order total will be isued. The balance will be invoiced after a further 28 days. If no date is specified above, we will consider the site delivery date to be **6 weeks after the date of your purchase order**.

Please note that your order will not be processed until we receive signed confirmation. Standard lead time for a Delts 1-12 is approximately 4-5 weeks, the Delta 14-16 lead time is approximately 5-6 weeks, however this is depenant on seasonal demand.

Certikin

Certikin International Ltd, Witan Park, Avenue 2, Station Lane Industrial Estate, Witney, Oxfordshire, OX28 4FJ United Kingdom

Sales Tel: 01993 778855 Admin Tel: 01993 777200 Website: www.certikin.co.uk Email: info@certikin.co.uk