Reference: 22782Cb



CERTIFICATE OF CONFORMITY

Product: Connector Kit CKE52

<u>Tested by request of</u> Kabelwerk Eupen A.G.

Malmedyerstrasse 9

4700 EUPEN Belgium

Manufactured at (name and place) Kabelwerk Eupen A.G.

Malmedyerstrasse 9

4700 EUPEN Belgium

Trade mark (if any): EUPEN

Model/Type Ref: Connector kit CKE52, Type 1 (5 kV; 25 Amp.), Class B (field

mounted) Style 2 & Style 9

Ratings and principal Connector CKE 52 in combination with the 3 PUR resins

characteristics: 1) ISO-PUR K760 from Iso-Elektra

2) SCOTCHCAST RESIN 40 from 3M 3) Type EG from Cellpack

and Airfield Lighting Primary Cable Type C 1x6 mm² 5kV

Additional information:

- Technical file connector kit: Connector kit CKE52, FAA L-823 Plug and Receptacle, Cable Connectors

Various samples of CKE connector kits in order to cover different type and manufacture of resin have been tested and found to be generally in conformity with:

FAA L-823: AC 150/5345-26E/2021

as shown in the test reports LA 23/0097-1

This Certificate of Conformity is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard. It does not imply an assessment of the whole production. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Brussels, 18/04/2023

C. LANA,

Certification Manage



SCSC SCS

SGS Belgium NV – Division SGS CEBEC Riverside Business Park Bld. Internationalelaan, 55 Build. K BE-1070 Brussels Tel. +32 2 556 00 20