Certificate of Compliance

Certificate: 80171602 **Master Contract:** 301803

Project: 80171602 **Date Issued:** 2025-04-14

Issued To: **ADB SAFEGATE Canada Inc.**
3375 North Service Road
Unit C5
Burlington, Ontario, L7N 3G2
Canada

Attention: Harman Dhillon

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Mike W. Gryschuk*
Mike W. Gryschuk, C.E.T.

PRODUCTS

CLASS 9032 02 - INSULATING DEVICES AND MATERIALS - Underground Cable Splicing Kits

Underground cable splicing kits for direct burial use, rain-tight, water-tight and submersible locations:
Series PRKEU0, rated 20A, 1500V for use with Nos 4-12 AWG copper conductors.
Series SCK, rated 20A max, 1500V for use with Nos 8-16 AWG copper conductors.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 198.2-23, 4th Ed - Sealed Wire Connector Systems

Notes:

Products certified under Class 9032 02 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

© 2018 CSA Group. All rights reserved.

Supplement to Certificate of Compliance

Certificate: 80171602 **Master Contract:** 301803

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80171602	2025-04-14	Original Certification Series PRKEU0, SCK.

© 2018 CSA Group. All rights reserved.